



Consumer Confidence Report Drinking Water System 2018



Commander, Fleet Activities Chinhae (CFAC)

This report meets Commander, Navy Installations Command Policy Letter 5200, Ser N4/13U84441, 15 Oct 13. This report reflects monitoring data collected in 2017 and will be updated annually.

이 보고서는 귀하의 식수에 대한 중요한 내용이 실려 있습니다. 그러므로 이 보고서를 이해할 수 있는 사람에게 번역해 달라고 부탁하시기 바랍니다.

Your Water is Fit for Human Consumption!

Commander, Fleet Activities Chinhae (CFAC) is pleased to provide this annual Consumer Confidence Report (CCR) for the CFAC Drinking Water System.

This report provides information about the water that was delivered throughout the Installation in 2017. It describes where the water comes from, what it contains, and how it compares to standards for safe drinking water. The goal is, and always has been, to provide safe and dependable drinking water.

Source of Water

CFAC drinking water comes from under the earth's surface (groundwater). Most groundwater comes from rain and melting snow soaking into the ground. Water fills the spaces between rocks and soils, making an aquifer. Aquifers can be located in underground soils or can occur in fractured bedrock located deep underground. The source water for CFAC is supplied from four (4) groundwater wells located within the Installation.

The CFAC water system is also connected to the city of Chinhae potable water system. The interconnection is opened in case of an emergency. The city of Chinhae provides treated and disinfected surface water. The water sources for the city are the Nakdong River and the Songju Reservoir. The water is treated at the Sokdong Water Treatment Plant. The water interconnection has not been used since it was installed in 2003.

For everyone's protection, CFAC continuously monitors groundwater for a wide variety of impurities to verify the water provided to our community meets both U.S. Federal and Korean standards. The treatment and distribution systems are monitored and secured at all times.

Water Treatment & Distribution System

The Public Works Department (PWD) Chinhae operates the water treatment and distribution system servicing this Installation. A 95,000-gallon

underground concrete raw water storage tank receives water from the four groundwater wells. Two pumps transfer the raw groundwater from the raw water tank into the water treatment plant (WTP). The groundwater is initially treated by four multimedia filters arranged in a series-parallel configuration. Following filtration to remove sediments, the raw groundwater is disinfected by an on-site liquid chlorine treatment to kill potentially harmful bacteria and viruses. The finished water is temporarily stored in a 20,000-gallon underground concrete tank or clear well. A 10,000-gallon spare water tank at the CFAC WTP serves as a back up to either the raw water tank or the finished water tank if either tank is out of service. The spare water tank provides full redundancy for uninterrupted operation when any component of the WTP requires inspection, maintenance, or repair. The treated water in the clear well is further treated by an air stripping tower to remove dissolved carbon dioxide and reduce corrosivity. The treated water is then stored in two (2) large tanks located at the top of a hill, above Upper Housing, for distribution across CFAC and for firefighting protection requirements.

Drinking Water Monitoring

U.S. Navy overseas installations are required to meet or exceed National Primary Drinking Water regulations promulgated under the Safe Drinking Water Act of 1974, which was adopted by Commander, Navy Installations Command (CNIC) Instruction 5090.1, and are the same standards used in the U.S. to ensure safe drinking water. CFAC is also required to meet all criteria established in the Korea Environmental Governing Standards (KEGS) 2012, intended to ensure Department of Defense (DoD) activities and installations in Korea protect human health and the natural environment through the promulgation of specific environmental compliance criteria. These standards require monitoring and testing of the drinking water for contaminants on a regular basis ensuring it is safe to drink.

Samples are analyzed for certain physical and chemical properties using field and laboratory equipment. The

PWD Chinhae conducts daily samplings and analysis and/or the remaining required analytical testing, per KEGS and CNICINST 5090.1, is conducted by SGS Laboratories, Inc.

CFAC's drinking water is monitored for and analyzed (analyzing agency shown in italics) for the following constituents at the frequencies shown below:

Daily (*PWD Chinhae*) – pH, Turbidity, Residual Chlorine, Temperature, and Conductivity

Monthly (*PWD Chinhae*) – Total Coliform

Quarterly (*Lab*) - PCBs, Herbicides, Pesticides, Organic Chemicals, Radionuclides

Semi-annually (*Lab*) – Lead and Copper

Annually (*Lab*) –Inorganic Chemicals, Corrosion Control, Nitrite/Nitrate, Disinfection By-Products (TTHM and HAA5)

The water samples are collected from water faucets and fountains located throughout CFAC. The following table provides the results of the above testing for 2017. If a particular contaminant was detected above unsafe levels it would be documented below.

Water Quality Data

In 2017, PWD Chinhae tested CFAC's drinking water for many possible contaminants. The following table lists the categories with which a particular contaminant is associated. The below results show that CFAC's drinking water complies with all the pertinent standards and as such is –

Fit for Human Consumption

Contaminant	Typical Sources	Unit of Measure	Regulatory Criteria – KEGS & CNICINST 5090.1		Laboratory Results			
			MCLG or MRDLG	MCL, TT or MRDL	Result*		Violation	
					Low	High		
Inorganics	Heavy Metals	Erosion of natural deposits	mg/L	0.0005 to 2.0	0.002 to 2.0	ND	0.034	No
	Total Nitrite & Nitrate	Run off from fertilizer use	mg/L	Nitrate 10.0 Nitrite 1.0	Nitrate 10.0 Nitrite 1.0	2.56*	2.56	No
	Asbestos	Decay of asbestos cement water mains; Erosion of natural deposits	MFL	7	7	ND	ND	No
	Fluoride	Discharge from plastic and fertilizer factories	mg/L	4.0	4.0	ND	ND	No
	Cyanide	Discharge from steel/metal factories; Discharge from plastic and fertilizer factories	mg/L	0.2	0.2	ND	ND	No
Organics	Volatile Organics	Discharge from industrial and agricultural chemical factories	mg/L	0.0 to 10.0	0.002 to 10	ND	ND	No
	Semi Volatile Organics & Pesticides /PCB	Run off from landfills; Discharge of waste chemicals; Runoff from herbicide used on crops and soil fumigants	mg/L	0.0 to 0.7	3×10^{-8} to 0.7	ND	ND	No
Microbiological	Turbidity	Soil runoff	NTU	NA	1 maximum & 0.3 for 95% of the monthly samples	0.05	0.17	No
	Total Coliform Bacteria	Naturally present in the environment	NA	0	No more than one positive sample per month	0 Negative	0 Negative	No
Disinfectant & Disinfection By-Products	Halo Acetic Acids (HAA5)	Byproduct of drinking water disinfection	mg/L	0.0 to 0.07	Annual average 0.06	ND	ND	No
	Total Tri-Halo-Methanes (TTHM)	Byproduct of drinking water disinfection	mg/L	0.0 to 0.07	Annual average 0.08	ND	ND	No
Radionuclide	Gross Alpha/Radium-226 and 228	Erosion of natural deposits	pCi/L	0	5 to 15	ND	ND	No

Contaminant	Typical Sources	Unit of Measure	Regulatory Criteria – KEGS & CNICINST 5090.1		Laboratory Results*		Violation
			MCLG	AL	Low	High	
Lead	Corrosion of household plumbing systems; erosion of natural deposits.	mg/L	0	0.015 based on 90 th percentile results exceeding AL	ND	0.0203	No
Copper	Corrosion of household plumbing systems; erosion of natural deposits.	mg/L	1.3	1.3 based on 90 th percentile results exceeding AL	0.0285	0.0852	No

Note *: Lowest and Highest Sample Reading collected in 2017.

Data Table Key: Unit Descriptions

mg/L	mg/L: number of milligrams of substance in one liter of water
ppm	ppm: parts per million, or milligrams per liter
ppb	ppb: parts per billion, or micrograms per liter
ppt	ppt: parts per trillion, or nanograms per liter
MFL	MFL: million fibers per liter (fibers greater than 10 micrometers in length)
NTU	NTU: nephelometric turbidity units
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)
NA	NA: not applicable
ND	ND: not detected
NR	NR: monitoring not required


Important Drinking Water Definitions

MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLG as feasible using the best available treatment technology.
TT	Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water systems must follow.
MRDLG	Maximum Residual Disinfectant Level Goal: The level of a drinking water disinfectant below which there is no known or expected risk to health (4 mg/L of chlorine). MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	Maximum Residual Disinfectant Level: The highest level of a disinfectant allowed in drinking water (4 mg/L of chlorine). There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Violations and Exceedances: None

You may obtain more information about contaminants and potential health effects by calling the EPA’s Safe Drinking Water Hotline 1-800-426-4791, or see their website at <http://water.epa.gov/drink/hotline/index.cfm>





Lastly, remember saving water is simple and inexpensive. Practicing a few of the following tips can make a difference in conserving our planet's most precious resource:

- Take short showers - a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month.
- Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- Call PWD Chinhae for repair of any water leaks; e.g., faucets and toilets.
- Visit www.epa.gov/watersense for more information.

For more information on this report, issues related to drinking water quality, or if you would like to review a complete listing of analytical results please contact PWD Chinhae Environmental Office (N45) at 762-5648.

General Information about Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants such as salts and metals that can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Organic chemical contaminants, including synthetic and volatile organic chemicals that are byproducts of industrial processes and petroleum production and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- Radioactive contaminants that can be naturally occurring or be the result of oil and gas production and mining activities.
- Pesticides and herbicides that may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Other Useful Information

Possible Source of Contaminants

As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals. It can also pick up other substances resulting from the presence of animals or human activity. Drinking water, including bottled water, may reasonably be expected to contain at least trace amounts of some contaminants.

The presence of contaminants does not necessarily indicate that the water poses a health risk. Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, persons with HIV/AIDS or other immune disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA and the Center for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the EPA Hotline at 1-800-426-4791.

Potential Contaminants

Lead

Elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our tap water did not exceed the lead drinking water health standards required by the KEGS. To take extra precaution in avoiding possible lead contamination, when water has been sitting for several hours, you can further minimize the potential for lead exposure by flushing the tap for 30 seconds to two minutes before using water for drinking or cooking. Information on lead in drinking water is available at <http://www.epa.gov/safewater/lead>.

Nitrate/Nitrite

Nitrates are naturally present in soil, water, and food. Nitrates themselves are relatively nontoxic. However, when swallowed, they are converted to nitrites that can react with hemoglobin in the blood creating methemoglobin. This methemoglobin cannot transport oxygen thus causing conditions of shortness of breath and blue baby syndrome. Our tap water did not exceed the Nitrate/Nitrite drinking water health standards required by the KEGS. Information on Nitrate in drinking water is available at <http://water.epa.gov/drink/contaminants/basicinformation/nitrate.cfm>

Arsenic

Arsenic is odorless and tasteless. It enters drinking water supplies from natural deposits in the earth or from agricultural and industrial practices. Some people who drink water containing arsenic in excess of the Maximum Contaminant Level (MCL) for many years could experience skin damage or problems with their circulatory system and may have an increased risk of getting cancer. Last year, as in years past, our tap water met the Arsenic drinking water health standards required by the KEGS. Information on Arsenic in drinking water is available at <http://water.epa.gov/drink/contaminants/basicinformation/arsenic.cfm>

Frequently Asked Questions

Why does the water sometimes look rusty?

Rusty or reddish tinted water may occur because of a sudden change in pressure which can cause rust in distribution piping to become dislodged. Iron causes the discoloration (rust is a secondary drinking water standard having mostly cosmetic or aesthetic effects) and it is not a health risk. If water looks rusty, flush the tap for three minutes or until clear before using water. Running the water will clear the piping system. If hot tap water is rusty, the water heater may need to be flushed.

I don't like the taste/smell/appearance of my tap water. What's wrong with it?

Even when water meets standards, you may still object to its taste, smell, or appearance. Taste, smell and appearance are also known as aesthetic characteristics and do not pose health risks. Common complaints about water aesthetics include: temporary cloudiness (typically caused by air bubbles) or chlorine taste (which can be improved by letting the water stand exposed to the air). If you want to improve the taste, smell and appearance of water, you can install a home water filter. Please keep in mind that filters require regular maintenance and replacement; if ignored, water taste, smell, or appearance issues may reoccur.

Is it okay to drink from a garden hose?

The water coming out of the tap and into the hose is safe but a garden hose is treated with special chemicals that make it flexible. Those chemicals are not good for you and neither are the bacteria that may be growing inside the hose.

