



# 2024 Annual Consumer Confidence Report Commander, Fleet Activities Chinhae (CFAC)



## Your Water is Fit for Human Consumption!

Commander, Fleet Activities Chinhae (CFAC) is pleased to provide this annual Consumer Confidence Report (CCR) for the CFAC Drinking Water System. Our goal is to provide to you a safe and dependable supply of drinking water. This report is based on the results of our monitoring for the period of January 1 to December 31, 2024. If you have any questions about the quality of water at CFAC or would like more information on the Overseas Drinking Water Program, please contact the Public Works Department (PWD), Environmental Division at 763-8752.

### Source of Water

Our drinking water comes from groundwater that lies deep under the earth's surface and consists mostly of rain and melting snow that has filtered through hundreds of feet of soil and rock. This water fills spaces between rocks and soils and creates an aquifer. Aquifers are underground bodies of water that can be located in underground soils or can occur in fractured bedrock deep underground. CFAC draws this water from four (4) groundwater wells located within the Installation.

### Water Treatment & Distribution System

The PWD Chinhae operates the water treatment and distribution system servicing this Installation. A 95,000-gallon underground concrete raw water storage tank receives water from the groundwater wells. Pumps transfer the raw groundwater from the raw water tank into the water treatment plant (WTP). The groundwater is treated by four multimedia filters arranged in a series-parallel configuration. Following filtration to remove sediments, the raw groundwater is disinfected by an on-site chlorine treatment that kills potentially harmful bacteria and viruses. The water is then treated by an air stripping tower that removes dissolved carbon dioxide and reduces corrosivity. The treated water is held in large storage tanks before entering the distribution system to the customers' tap.

### Overseas Drinking Water Program

U.S. Navy overseas installations are required to meet or exceed the National Primary Drinking Water regulations promulgated under the Safe Drinking Water Act of 1974, adopted in Commander, Navy

Installations Command (CNIC) Manual 5090 Series, to ensure safe drinking water. CFAC is also required to meet all criteria established in the Korea Environmental Governing Standards (KEGS) to protect the quality of drinking water at the U.S. installations.

The Installation Commanding Officer has established an Installation Water Quality Board (IWQB) tasked with ensuring there is a reliable supply of drinking water for all persons using CFAC facilities. The IWQB is currently taking steps to meet all requirements of the Navy's Overseas Drinking Water (ODW) program. The Regional Water Quality Board (RWQB) granted CFAC a Conditional Certificate To Operate (CTO) for its water system. CFAC is expected to receive a Full CTO when all deficiencies identified from the 2023 Sanitary Survey are corrected. The deficiencies have either been corrected or are in the process of implementing corrective actions.

### Source Water Assessment

In June 2023, the Navy Water Quality Oversight Council (WQOC) conducted a comprehensive sanitary survey of the CFAC drinking water system. Sanitary surveys are performed every three years and evaluate eight elements of an ODW system for the adequacy of the drinking water source, treatment, distribution system, finished water storage, facilities, monitoring & reporting, operation & maintenance, and operators for producing and distributing safe drinking water. CFAC is continually improving the drinking water system based on the recommendations contained in the 2023 sanitary survey report. The next sanitary survey is to be conducted in the year 2026.

### Potential Contaminants

As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include bacteria, organic and inorganic chemicals, and radionuclides. Drinking water, including bottled water, may reasonably be expected to contain at least trace amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. Some people may be more vulnerable to contaminants

in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, persons with HIV/AIDS or other immune disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA and the Center for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the EPA Hotline at 1-800-426-4791. In 2024, our drinking water met health standards established by both U.S. EPA regulations and KEGS for all listed contaminants.

## **Other Potential Contaminants**

### **Coliforms in Drinking Water**

Coliforms are bacteria that are naturally present in the environment and used as an indicator for other potentially harmful bacteria that may be present in drinking water. It is a warning of potential problems if coliforms are found in more water samples than allowed. Information on total coliforms in drinking water is available at

<https://www.epa.gov/dwreginfo/revised-total-oliform-rule-and-total-coliform-rule>.

### **Lead**

Elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. To take extra precaution in avoiding possible lead contamination, when water has been sitting for several hours, you can further minimize the potential for lead exposure by flushing the tap for 30 seconds to two minutes before using water for drinking or cooking. Information on lead in drinking water is available at

<http://www.epa.gov/safewater/lead>.

### **Lead in Priority Areas**

For the safety and wellness of youth at the Youth Center, all drinking water outlets are tested every five years or whenever outlets are added or replaced. In 2024, a five-year recurring sampling was conducted and drinking water samples were collected from outlets at the Youth Center. All sampling results were reported below CNIC required screening level of 10 ppb for lead per CNIC Instruction 5090.6A.

## **Nitrate/Nitrite**

Nitrates are naturally present in soil, water, and food. Nitrates themselves are relatively nontoxic. However, when swallowed, they are converted to nitrites that can react with hemoglobin in the blood creating methemoglobin. This methemoglobin cannot transport oxygen thus causing conditions of shortness of breath and blue baby syndrome. Information on Nitrate in drinking water is available at

<http://water.epa.gov/drink/contaminants/basicinformation/nitrate.cfm>.

## **What are per- and polyfluoroalkyl substances and where do they come from?**

Per- and polyfluoroalkyl substances (PFAS) are a group of thousands of man-made chemicals. PFAS have been used in a variety of industries and consumer products around the globe, including in the U.S., since the 1940s. PFAS are found in many consumer products, as well as in industrial products, like certain firefighting agents called aqueous film forming foam (AFFF). PFAS is also found in essential use applications such as in microelectronics, batteries, and medical equipment. PFAS chemicals are persistent in the environment, and some are persistent in the human body – meaning they do not break down and they can accumulate over time. Information on PFAS in drinking water is available at

<https://www.epa.gov/pfas/our-current-understanding-human-health-and-environmental-risks-pfas>

## **Total Trihalomethanes (TTHM) and Haloacetic Acids (HAA5)**

TTHM and HAA5 are groups of chemicals formed when the naturally occurring organic materials in raw water reacts with the chlorine which is added as disinfectant. Potential health effects from exposure to TTHM and HAA5 depend on a variety of factors, including concentration of the chemicals, and duration and frequency of exposure. Some people who drink water containing TTHMs in excess of the MCL over many years may experience liver, kidney or central nervous system problems and increased risk of cancer. Information on the byproducts is available at

<https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants#Byproducts>

## Frequently Asked Questions

### Why does the water sometimes look rusty?

Rusty or reddish tinted water may occur because of a sudden change in pressure which can cause rust in distribution piping to become dislodged. Iron causes the discoloration (rust is a secondary drinking water standard having mostly cosmetic or aesthetic effects) and it is not a health risk. If water looks rusty, flush the tap for three minutes or until clear before using water. If hot tap water is rusty, the water heater may need to be flushed. Users can report hot tap water that is rusty to Family Housing or to the building manager.

### I don't like the taste/smell/appearance of my tap water. What's wrong with it?


Even when water meets standards, you may still object to its taste, smell, or appearance. Taste, smell and appearance are also known as aesthetic characteristics and do not pose health risks. Common complaints about water aesthetics include: temporary cloudiness (typically caused by air bubbles) or chlorine taste (which can be improved by letting the water stand exposed to the air). If you want to improve the taste, smell and appearance of water, you can install a home water filter. Please keep in mind that filters require regular maintenance and replacement; if ignored, water taste, smell, or appearance issues may reoccur. Users can report taste, smell and appearance of water to Family Housing or to the building manager.

### What is water hardness?

Water hardness is an aesthetic quality of water, and is caused mostly by the minerals calcium and magnesium, but is classified or measured based on the level of concentration of calcium carbonate. CFAC water is moderately hard, containing approximately 80 mg/L. Generally, 0-75 mg/L is soft, 75-150 mg/L is moderately hard, 150-300 mg/L is hard, and 300 mg/L or more is very hard.

### Is it okay to drink from a garden hose?

The water coming out of the tap and into the hose is safe but a garden hose is treated with special chemicals that make it flexible. Those chemicals are not good for you and neither are the bacteria that may be growing inside the hose. An ordinary garden hose submerged in a bucket of water or swimming pool can result in backflow contamination. To protect our



water supply, a simple screw-on vacuum breaker (photo) must always be attached to the faucet when a garden hose is used.

### Is there a regulation for PFAS in drinking water?

On April 26, 2024, the U.S. EPA published a National Primary Drinking Water Regulation (NPDWR) final rule on drinking water standards for six PFAS under the Safe Drinking Water Act (SDWA). The rule establishes the following maximum contaminant levels (MCLs):

Compound	MCL	Hazard index (MCL)
PFOS	4 ppt	NA
PFOA	4 ppt	NA
Gen X (HFPO-DA)	10 ppt	1 (unitless)
PFNA	10 ppt	
PFHxS	10 ppt	
PFBS	NA	

Under the NPDWR, regulated public water systems (PWS) are required to complete initial monitoring by April 26, 2027. Beginning April 26, 2027, regulated PWSs will conduct ongoing compliance monitoring in accordance with the frequency dictated by the rule and as determined by the initial compliance monitoring results. Regulated PWSs must demonstrate compliance with the MCLs by April 26, 2029. In order to provide safe drinking water to all Department of Defense (DoD) personnel, OSD policy extends this requirement to all DoD systems which provide drinking water for human consumption, regardless of size of the drinking water system. In addition to the six regulated compounds, DoD-owned systems are required by DoD policy to monitor for all 25 compounds detected when using EPA Method 533. Protecting the health of our personnel, their families, and the communities in which we serve is a priority for CFAC. DoD is committed to complying with requirements of the NPDWR and the continued provision of safe drinking water to those that work and live on DoD installations.

### Has CFAC tested its water for PFAS?

Yes. In June 2024 and December 2024, samples were semi-annually collected from the WTP, B802. We are informing you that 3 of the 25 PFAS covered by the sampling method were detected in the water system. The results are provided in the below table. EPA does not have an MCL for all of these compounds at this time. PFOA, PFOS, PFNA, PFHxS, PFBS, and Gen X were not detected.

### What is next?

CFAC will continue to monitor for PFAS in accordance with the EPA regulation and DoD policy. Once required initial monitoring information is available, we will calculate the Running Annual Averages (RAA) for the regulated PFAS and will compare those numbers to the MCL and Hazard Index (HI) trigger levels. This will determine what our continuing monitoring requirements will be beginning in 2027, and if needed, we will plan operational or infrastructure changes to ensure our water complies with the PFAS MCLs and HI by April 2029 in accordance with the SDWA.

### Water Quality Monitoring

CFAC uses Navy Operator Certification Authority (NOCA) approved laboratory methods to analyze our drinking water for the following potential contaminants at the frequencies required by regulation.

Group	Potential Contaminants	Frequency of Sampling
<b>Micro-organisms</b>	Total Coliform	Monthly
<b>Disinfectants</b>	Residual Chlorine	Hourly, Daily, Monthly
<b>Disinfection By products</b>	TTHM/HAA5	Annually
<b>Inorganic Chemical</b>	Metals, Nitrate/Nitrite, Lead & Copper	Every 3 years, Annually, Annually
<b>Organic Chemical</b>	Synthetic (Volatile and Pesticides)	Quarterly
<b>Radionuclides</b>	Alpha Particles, Radium, Uranium	Every 4 years

## 2024 Water Quality Data

In 2024, PWD Chinhae tested CFAC's drinking water for many possible contaminants. The following table lists the categories with which a particular contaminant is associated. The below results show that CFAC's drinking water complies with all the pertinent standards.

REGULATORY CRITERIA – KEGS & CNIC M 5090.1				LABORATORY RESULTS		
Contaminant	Typical Sources	Unit	MCL, AL, TT or MRDL	Results		Violation
				Low	High	
MICROBIOLOGICAL						
Total Coliform	Naturally present in the environment	NA	No more than one positive sample per month	Negative	Negative	No
DISINFECTANT RESIDUAL AND DISINFECTANT/DISINFECTION BYPRODUCTS						
Residual Chlorine	Water additive used to control microbes	mg/L	MRDL = 4.0	0.22	0.48	No
Halo Acetic Acids (HAA5)	Byproduct of drinking water disinfection	mg/L	Annual average 0.06	ND	ND	No
Total Trihalomethanes (TTHM)		mg/L	Annual average 0.08	ND	0.0027	No
INORGANIC CHEMICALS						
Nitrate (as N)	Runoff from fertilizer use; leaking from septic tanks; Sewage; Erosion of natural deposits	mg/L	10	2.24		No
Nitrite (as N)		mg/L	1	ND		No
Lead	Corrosion of household plumbing systems; erosion of natural deposits.	µg/L	15 based on 90 <sup>th</sup> percentile results exceeding AL	0.25		No

<b>Copper</b>		µg/L	1,300 based on 90 <sup>th</sup> percentile results exceeding AL	73		<b>No</b>
<b>SYNTHETIC ORGANIC CHEMICALS (SOCs)</b>						
<b>Semi Volatile Organics &amp; Pesticides /PCB</b>	Run off from landfills; discharge of waste chemicals; runoff from herbicide used on crops and soil fumigants	mg/L	3x10 <sup>-8</sup> to 0.7	ND	ND	<b>No</b>
<b>Volatile Organics</b>	Discharge from industrial and agricultural chemical factories	mg/L	0.002 to 10	ND	ND	<b>No</b>

PFAS Contaminant		Typical Sources	MCL* (ppt)	Results	Action
				(ppt)	
11Cl-PF3OUdS	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	Food packaging, stain resistant, nonstick products, water repellents, waxes, paints, cleaning products, firefighting foams	NA	ND	No Action Needed
4:2FTS	1H, 1H, 2H, 2H-Perfluorohexanesulfonic Acid		NA	ND	
6:2 FTS	1H, 1H, 2H, 2H-Perfluorooctanesulfonic Acid		NA	ND	
8:2 FTS	1H, 1H, 2H, 2H-Perfluorodecanesulfonic Acid		NA	ND	
9Cl-PF3ONS	9-Chlorohexadecafluoro-3-oxanone-1-sulfonic acid		NA	ND	
ADONA	4,8-Dioxa-3H-perfluorononanoic acid		NA	ND	
HFPO-DA (Gen X)	Hexafluoropropylene oxide dimer acid		10	ND	
NFDHA	Nonafluoro-3,6-dioxaheptanoic Acid		NA	ND	
PFBS	Perfluorobutanesulfonic acid		NA	ND	
PFDA	Perfluorodecanoic acid		NA	ND	
PFHxA	Perfluorohexanoic acid		NA	3.9	
PFBA	Perfluorobutanoate		NA	8.1	
PFEESA	Perfluoro(2-ethoxyethane) Sulfonic Acid		NA	ND	
PFHpS	Perfluoroheptane Sulfonate		NA	ND	
PFMBA	Perfluoro-4-methoxybutanoic Acid		NA	ND	
PFMPA	Perfluoro-3-methoxypropanoic Acid		NA	ND	
PFPeA	Perfluoropentanoate		NA	12	
PFPeS	Perfluoropentane Sulfonic Acid		NA	ND	
PFDoA	Perfluorododecanoic acid		NA	ND	
PFHpA	Perfluoroheptanoic acid		NA	ND	
PFHxS	Perfluorohexanesulfonic acid		10	ND	
PFNA	Perfluorononanoic acid		10	ND	
PFOS	Perfluorooctanesulfonate		4	ND	
PFOA	Perfluorooctanoic acid		4	ND	
PFUnA	Perfluoroundecanoic acid		NA	ND	

\* Regulated PWSs must demonstrate compliance with these MCLs by April 26, 2029



## Terms and Abbreviations

You may find unfamiliar terms and abbreviations in the tables below and throughout the document. To help you better understand these terms we've provided the following definitions:

### Data Table Key: Unit Descriptions

mg/L	milligrams per liter, or parts per million (ppm)
µg/L	micrograms per liter, or parts per billion (ppb)
ppt	ppt: parts per trillion, or nanograms per liter (ng/L)
NA	Not Applicable
ND	Not Detected

### Important Drinking Water Definitions

MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLG as feasible using the best available treatment technology.
TT	Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	Action Level: The concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water systems must follow.
MRDL	Maximum Residual Disinfectant Level: The highest level of a disinfectant allowed in drinking water (4 mg/L of chlorine). There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
90 <sup>th</sup> percentile	Represents the highest value found out of 90 percent of the samples taken. If the 90th percentile value is greater than the AL, a treatment evaluation and/or mitigation actions must be conducted on the water system.